

DECLARATION OF PERFORMANCE

Product unique identification code	DALM3000, DALM5000
Product usage	Alarm transmission and fault warning routing equipment for fire alarm systems installed in buildings
Manufacturer	AddSecure AB Telefonvägen 26 126 26 Hägersten Stockholm, Sweden
Name and contact address for authorized representative	Not Applicable
System of assessment and verification of constancy of performance	System 1
Name and identification number of the notified body	DBI Certification A/S, 2531
European Technical Assessment Body	Not applicable

Declared Performance

Type:

DALM 3000 and DALM 5000

Alarm transmission and fault warning routing equipment

The certified products are only approved for dedicated alarm paths (Type 1).

The alarm transmitter is powered from an external power source and is intended to be powered from a CIE which in turn is powered by a power source according to EN 54-4. The output for monitoring of processing must be externally monitored by the associated CIE.

Performance

Essential characteristics	Clauses in EN 54-21:2006	Performance
Performance of transmission	4, 5	Passed
Operational reliability	4, 5, 7, 8, 9	Passed
Durability of operational reliability, temperature resistance	10.4	Passed
Durability of operational reliability, vibration resistance	10.6, 10.7, 10.11	Passed
Durability of operational reliability, electrical stability	10.8, 10.9	Passed
Durability of operational reliability, humidity resistance	10.5, 10.10	Passed

Signed for and on behalf of the manufacturer by Andrew Hunneman, Director R&D, AddSecure AB.



Director R&D
9th November 2022