



Certificate of Conformity

Product Certification Scheme 1B

Certificate No. 31354-01-23-INT

This certificate applies to the products

Supervise Premises Transceiver (SPT)

with name and/or type designation

DALM1000 IP/4G

DALM3000 IP/4G

DALM5000 IP/4G

Placed on the market by

AddSecure AB

Telefonvegen 26, 126 26 Hagersten, Sweden

This certificate attests that all provisions concerning the assessment and the performance described in the standards

EN 50131-10:2014

EN 50136-2:2013

are applied and that the products fulfils all the prescribed requirements

This Certificate is valid until 2027-08-25

Høvik, Norway 2023-08-25

For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen, Certification Manager



Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2027-08-25

Products Covered by this Certificate		
Product Name	Product Description	Applied Standards
DALM1000 IP/4G	SPT Dual ATP: Ethernet/GPRS	EN 50131-10:2014 EN 50136-1:2012/A1:2018 EN 50136-2:2013
DALM3000 IP/4G		
DALM5000 IP/4G		

Product Specifications		
Product Name	ATS Classification EN 50136-1:2012	ATS Configuration EN 50131-10:2014
DALM1000 IP/4G	SP2 DP1 Primary ATP: Ethernet Secondary ATP: GPRS	Type X or Type Y
DALM3000 IP/4G	SP6 DP4 Primary ATP: Ethernet Secondary ATP: GPRS	
DALM5000 IP/4G	SP6 DP4 Primary ATP: Ethernet Secondary ATP: GPRS	

Application/Limitation

- Suitable for indoor application
- When the SPT is Type Y, the product is intended to be installed inside an enclosure of another intrusion alarm component.
For the purposes of conforming to EN 50131-10:2014 and EN 50136-2:2013 the enclosure shall be that of a CIE conforming to EN 50131-3:2009 and/or the power supply equipment conforming to EN 50131-6:2017/A1:2021
- To be used in accordance with the supplier's installation and operation instructions
- Security Grade 1-4: when used as ATS configuration Type Y. Security grade depending on the minimum security grade of the enclosure and the power supply
- Security Grade 2: when used as ATS configuration Type X
- Environmental Class I

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Documents Reviewed	
Document ID	Description
9P00809 rev.1	Test report according to: EN 50136-1:2012 EN 50136-2:2013 EN 50131-10:2014
30019	Test report according to: EN 50131-10

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plant
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE